



CITY OF FOUNTAIN VALLEY BUILDING DEPARTMENT

SKYLIGHT REQUIREMENTS

714/593-4429

ONE HOUR OCCUPANCY SEPARATION WALL

<p>GENERIC FLOOR PLAN TYPICAL HOUSE</p>	<p>GARAGE</p> <p>WILL YOU BE CUTTING ANY RAFTERS? <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p>IF YES, SUBMIT DRAWING/CALCS.</p> <p>IS SKYLIGHT OPENABLE? <input type="checkbox"/> YES ** <input type="checkbox"/> NO</p> <p>SKYLIGHT MAKE/MODEL# _____</p> <p>SKYLIGHT ICC/ESR# _____</p> <p>IS THERE A SHAFT? <input type="checkbox"/> YES ** <input type="checkbox"/> NO</p> <p>** IF YES, SUBMIT DETAILS DRAWINGS/DETAILS</p>
---	---

USE THE ABOVE PLAN AND SHOW LOCATION AS CLOSE AS YOU CAN ON THE GENERIC FLOOR PLAN/TYPICAL HOUSE.

**IF SKYLIGHT IS OPENABLE, VENTS MUST BE IN COMPLIANCE WITH THE 2007 CALIFORNIA PLUMBING CODE REGARDING THE VENT TERMINATION. EACH VENT SHALL TERMINATE NOTLESS THAN 10'-0" FROM OR AT LEAST 3'-0" ABOVE ANY OPERABLE WINDOW, DOOR, OPENING AIR INTAKE, OR VENT SHAFT.

PLEASE NOTE, VENT LOCATION & DISTANCE FROM OCCUPANCY SEPARATION ON ABOVE FLOOR PLAN.

IF THE NEW ROOFING MATERIAL EXCEEDS 6 LBS/SQFT DEAD LOAD, ENGINEERING DESIGN FOR THE ROOF STRUCTURE IS REQUIRED.

Revised 2.10.2010